
## **WIRING DIAGRAM**

## WR 310





## **WIRING DIAGRAM**

## **WR 310**



A - Ventilation unit WR 310/410, WS 320/470

A1 - Electronic slide-in module

A2 - Controlled domestic ventilation unit control

B - Simple control unit RLS 1 WR

B2-B5 - Parallel connection max. 5 RLS 1 WR

BT1 - RLS T1 WS touchscreen control unit

W1 - 230 V AC connecting cable

W2 - Screened control cable for simple control unit (provided by customer), e.g. LIYY 6 x 0.34 mm<sup>2</sup>

W2 - Screened control cable RLS T1 WS (provided by customer), e.g. LIYY 4 x 0.34 mm²

W5 - Connecting cable for PTC heat register

W6 Connecting cable (provided by customer) for multi-function contact (potential-free relay contact 230 VAC/5A or 30 VDC/5A). Multi-function contact for connecting one of the following components: Alarm display, filter change message, operating display, supplementary heating, pre-heating, shutter, brine EHE (uncontrolled pump), cooling.

W7 - Connecting cable for bypass motor

S1 - Unit switch

M1 - Exhaust air/outgoing air fan

M2 - Outside air/supply air fan

M3 - Bypass motor

T-LET - Temperature sensor for air inlet for outside air

T-FOL - Temperature sensor for outgoing air

T-ZUL - Temperature sensor for supply air

S-ABL - Combination sensor for exhaust air